

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

APPLICATION OF LOVELACEVILLE WATER)	
COMPANY FOR A DEVIATION PURSUANT)	CASE NO.
TO 807 KAR 5:066, SECTION 4(4),)	93-413
REGARDING WATER STORAGE)	

O R D E R

On October 27, 1993, Lovelaceville Water Company ("Lovelaceville") filed a letter requesting a permanent deviation from Commission Regulation 807 KAR 5:066, Section 4(4), which requires that each utility shall maintain water storage to ensure a minimum of one day's average usage.

After a review of the request and being otherwise sufficiently advised, the Commission finds that good cause has not been shown to justify a permanent deviation. Lovelaceville received a temporary deviation from our water storage requirements in Case No. 92-527¹ which will expire January 1, 1998. Lovelaceville should review its water storage requirements prior to the expiration of the previously granted deviation and, if warranted, Lovelaceville may renew its request for a permanent deviation at that time.

IT IS THEREFORE ORDERED that Lovelaceville's request for a permanent deviation be and it hereby is denied.


¹ Case No. 92-527, Application of Lovelaceville Water Company for a Deviation Pursuant to 807 KAR 5:066, Section 4(4), Regarding Water Storage. Final Order dated February 9, 1993.

Done at Frankfort, Kentucky, this 12th day of January, 1994.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director